



NOTES:

1. Contractor to use Meg-A-Lug joint restraint on fittings.
2. No discharge from blow-off should go directly into a creek.
3. Provide erosion and sedimentation control for discharge.
4. Use Dead End Fire Hydrant detail 514.03 for water mains larger than 24".
5. All 2" pipe to be with iron pipe threads.



Department of Utilities
10455 Armstrong Street
Fairfax, VA 22030-3630

CITY of FAIRFAX
USE WITH THE FAIRFAX STANDARD SPECIFICATIONS ONLY

Voice (703) 385-7920
FAX (703) 934-8427
www.fairfaxva.gov

PERMANENT BLOW-OFF ASSEMBLY FOR WATER MAINS UP TO 24"

SCALE:
Not To Scale

REVISION DATE:
July, 2005

DETAIL #
2514.07

SHEET #:
1 of 1